



NOTES:

1. IN TRAFFIC LOAD SITUATIONS, COVER & BOX SHALL BE APPROVED BY CITY ENGINEER.
2. METER BOX TO BE LOCATED ON THE RIGHT-OF-WAY SIDE OF PROPERTY LINE
3. WHEN METER BOX IS SET IN SIDEWALK, PIGTAIL TO EXTEND 2 FEET BEYOND EDGE OF SIDEWALK.
4. FITTING TO BE USED WHEN CONNECTING TO EXISTING SERVICE, OTHERWISE CRIMP END OF SERVICE LINE.
5. FULLY ENCOMPASS CORPORATION STOP WITH STONE.
6. DO NOT EXCEED ALLOWABLE DIRECT TAP ALLOWED BY PIPE MANUFACTURER. OTHERWISE, USE DOUBLE STRAP SERVICE SADDLE.



THE CITY OF LYNCHBURG

2-INCH WATER SERVICE
(1 1/2-INCH WATER SERVICE SIMILAR)

USE WITH THE CITY OF LYNCHBURG STANDARD SPECIFICATIONS ONLY

SCALE:
NOT TO SCALE

REVISION DATE:
11-06-2006

DETAIL #
26.13

SHEET #:
1 OF 1